



Address: 2560 Corporate Place, D203, Monterey Park, CA 91754 TEL: (323) 980-8505 FAX: (323) 980-8503 WEB: www.emagineconcept.com

Rent Cabinet	Yes
Closed/Locked Cabinet	Yes
Building Type	Single building,
Building structure earthquake-proof	Yes

Connectivity:

One Wilshire 4th floor meet-me-room	yes, 4x8 cage and 96 strands of fiber cross connect- T1, E1, DS3, OC3, E3, Fiber
-------------------------------------	---

Internet Access	yes, bandwidth on demand
-----------------	--------------------------

List of carriers in co-location site	MCI On Fiber Quest XO Communications Teleshpere Cogent
--------------------------------------	---

List of carriers in building "Meet-me-room"	AEA Plus Telecom Air Power Cogent FiberNet Inovative Comm. Tech. MCI WorldCom Metromedia Fiber Networks Network Services System NextLink Prime Networks Q-Link Southern Calif. Edison
--	--



Address: 2560 Corporate Place, D203, Monterey Park, CA 91754 TEL: (323) 980-8505 FAX: (323) 980-8503 WEB: www.emagineconcept.com

	Total Call
	Universal Access
	Web Vision
	WebWay
	WorldAccess
	Network Integration Services
Rooftop access	yes, negotiable with landlord
"Meet me" room	Yes
Vertical clearance from raised floor	
Foot	10"
Meters	3.05 m.
Door width	70" to check
Foot	
Meters	
Floor load	250 pounds/sq. ft.
Air temperature	
Fahrenheit	65 o F more or less 2 o F
Celsius	18.3 o C more or less 1.1 o C
Humidity	50% more of less 5%
Air Filtration	Yes
Smoke and fire detection system	Yes
Fire suppression system	Pre-activation – Dry System
24/7 Security presence	24/7 (Building security)
Biometric recognition	No
Video surveillance	Yes
Guaranteed uptime (SLA)	yes

Electricity offering:



Address: 2560 Corporate Place, D203, Monterey Park, CA 91754 TEL: (323) 980-8505 FAX: (323) 980-8503 WEB: www.emagineconcept.com

· Total Power	750 kva
· Number of distinct power source	1
· AC	Yes
· DC	Yes
· Generator backup	Yes – Diesel
· Generator Life (hour)	72 hours+
· UPS/Battery Backup	Yes
· Battery Life (hour) (AC)	30 minutes at full capacity
· Backup Power Tested	
- Load test	Every 6 months
- No load test	Weekly
Minimum Power per electric circuit	20 Amperes
Standard Lead Time	
· Cabinet	2 business days
24/7 Onsite Access	Yes
Access Controls	Numeric key pad

Technical support:

Technical Support on site presence

· Level 1	Business hours
· Level 2	Business hours

Technical Support on call support

· Level 1	24/7
· Level 2	24/7